

Report Transmission Cover Page

Bill To: School District #35 20260 - 64 Avenue Langley, BC, Canada V3A 4P7	Project ID: Project Name: Project Location: LSD: P.O.: S00023 Proj. Acct. code:	Lot ID: 1498495 Control Number: Date Received: Jun 10, 2021 Date Reported: Jun 16, 2021 Report Number: 2631421
Attn: Accounts Payable Sampled By: Company:		

Contact	Company	Address
Accounts Payable	School District #35	20260 - 64 Avenue Langley, BC V3A 4P7 Phone: (604) 534-3294 Fax: Email: invoices@sd35.bc.ca
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge Reports	PDF	COC / Invoice
Terry Walker	School District #35	20260 - 64th Ave Langley, BC V3A 4P7 Phone: (604) 534-3294 Fax: (604) 534-0841 Email: tewalker@sd35.bc.ca
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge Reports	PDF	COC / Test Report
Email - Single Report	PDF	COA
Email - Single Report	PDF	Invoice

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report


Bill To: School District #35
 20260 - 64 Avenue
 Langley, BC, Canada
 V3A 4P7
 Attn: Accounts Payable
 Sampled By:
 Company:

Project ID:
 Project Name:
 Project Location:
 LSD:
 P.O.: S00023
 Proj. Acct. code:

Lot ID: **1498495**
 Control Number:
 Date Received: Jun 10, 2021
 Date Reported: Jun 16, 2021
 Report Number: 2631421

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7522713	ACSS / 159 S / 15.8 °C / S	0.00052	0.005	Below MAC
7522714	ACSS / 159 / 15.8 °C / F	0.00015	0.005	Below MAC
7522715	ACSS / Rm. 106 / 15.8 °C / S	0.0014	0.005	Below MAC
7522716	ACSS / Rm. 106 / 15.8 °C / F	0.00044	0.005	Below MAC
7522717	ACSS / Staff Rm. / 15.8 °C / S	0.00008	0.005	Below MAC
7522718	ACSS / Staff Rm / 15.8 °C / F	0.00004	0.005	Below MAC

Approved by: 
 Max Hewitt
 Operations Manager

Methodology and Notes

Bill To: School District #35 20260 - 64 Avenue Langley, BC, Canada V3A 4P7	Project ID: Project Name: Project Location: LSD: P.O.: S00023 Proj. Acct. code:	Lot ID: 1498495 Control Number: Date Received: Jun 10, 2021 Date Reported: Jun 16, 2021 Report Number: 2631421
Attn: Accounts Payable Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (VAN)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	Jun 11, 2021	Element Vancouver

References

US EPA US Environmental Protection Agency Test Methods

Guidelines

Guideline Description Health Canada GCDWQ
 Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, Sept 2020
 Guideline Comments MAC = Maximum Acceptable Concentration
 AO = Aesthetic Objective
 OG = Operational Guideline for Water Treatment Plants
 (does not apply to private groundwater wells).
 Refer to Health Canada for complete guidelines at www.hc-sc.gc.ca

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.
 Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.