

**Report Transmission Cover Page**

Bill To: School District #35 20260 - 64 Avenue Langley, BC, Canada V3A 4P7	Project ID: Project Name: Project Location: LSD: P.O.: S00023 Proj. Acct. code:	Lot ID: <b>1498495</b> Control Number: Date Received: Jun 10, 2021 Date Reported: Jun 16, 2021 Report Number: 2631423
Attn: Accounts Payable Sampled By: Company:		

Contact	Company	Address
<b>Accounts Payable</b>	<b>School District #35</b>	20260 - 64 Avenue Langley, BC V3A 4P7 Phone: (604) 534-3294 Fax: Email: invoices@sd35.bc.ca
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge Reports	PDF	COC / Invoice
<b>Terry Walker</b>	<b>School District #35</b>	20260 - 64th Ave Langley, BC V3A 4P7 Phone: (604) 534-3294 Fax: (604) 534-0841 Email: tewalker@sd35.bc.ca
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge Reports	PDF	COC / Test Report
Email - Single Report	PDF	COA
Email - Single Report	PDF	Invoice

**Notes To Clients:**

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

## Analytical Report

Bill To: School District #35  
 20260 - 64 Avenue  
 Langley, BC, Canada  
 V3A 4P7  
 Attn: Accounts Payable  
 Sampled By:  
 Company:

Project ID:  
 Project Name:  
 Project Location:  
 LSD:  
 P.O.: S00023  
 Proj. Acct. code:

Lot ID: **1498495**  
 Control Number:  
 Date Received: Jun 10, 2021  
 Date Reported: Jun 16, 2021  
 Report Number: 2631423

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7522727	LSS / Rm. 187 / 15.8 °C / S	0.0012	0.005	Below MAC
7522728	LSS / Rm. 187 / 15.8 °C / F	0.00098	0.005	Below MAC
7522729	LSS / Rm. 184 / 15.8 °C / S	0.00086	0.005	Below MAC
7522730	LSS / Rm. 184 / 15.8 °C / F	0.00036	0.005	Below MAC
7522731	LSS / Rm. 93 / 15.8 °C / S	0.00045	0.005	Below MAC
7522732	LSS / Rm. 93 / 15.8 °C / F	0.00022	0.005	Below MAC
7522733	LSS / Rm. 143 / 15.8 °C / S	0.0021	0.005	Below MAC
7522734	LSS / Rm. 143 / 15.8 °C / F	0.0060	0.005	Above MAC

Approved by:   
 Max Hewitt  
 Operations Manager

### Methodology and Notes

Bill To: School District #35 20260 - 64 Avenue Langley, BC, Canada V3A 4P7	Project ID: Project Name: Project Location: LSD: P.O.: S00023 Proj. Acct. code:	Lot ID: <b>1498495</b> Control Number: Date Received: Jun 10, 2021 Date Reported: Jun 16, 2021 Report Number: 2631423
Attn: Accounts Payable Sampled By: Company:		

### Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (VAN)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8	Jun 11, 2021	Element Vancouver
Trace Metals (extractable) in Water (VAN)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8	Jun 16, 2021	Element Vancouver

*\* Reference Method Modified*

### References

US EPA                      US Environmental Protection Agency Test Methods

### Guidelines

Guideline Description    Health Canada GCDWQ  
 Guideline Source        Guidelines for Canadian Drinking Water Quality, Health Canada, Sept 2020  
 Guideline Comments    MAC = Maximum Acceptable Concentration  
                                   AO = Aesthetic Objective  
                                   OG = Operational Guideline for Water Treatment Plants  
                                   (does not apply to private groundwater wells).  
                                   Refer to Health Canada for complete guidelines at [www.hc-sc.gc.ca](http://www.hc-sc.gc.ca)

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.  
 Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.