

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	35 - Langley
School Name:	Glenwood Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2024-07-08
	Date of next inspection: 2025-07-09
	Date and type of most recent maintenance: Furnace inspections and gym AHU serviced.
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: 2 hour morning fresh air flush.
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): MERV-13
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: School was upgraded to DDC HVAC controls. (Delta Type) 06/25/2022
Other Relevant Information:	Delta Controls
District Contact for any Questions:	Name: Brad Cairns
	Phone Number: 604-830-6367

Email: brcairns@sd35.bc.ca